

DEPUTY MINISTRY OF TOURISM

HOTEL ESTABLISHMENTS WITH FACILITIES FOR PEOPLE WITH ACCESS NEEDS

Name of the establishment:	EURONAPA		
Category:	HOTEL APARTMENTS		
Website:	www.euronapahotel.com		
Address:	6 John Kennedy Str., Agia Napa		
Date of inspection:	25/10/2017		
Facilities			
1	Parking Facilities for persons with disabilities		
1.1	Number of available parking spaces for persons with disabilities? (min. dimensions 3.30X5m)	2	
1.2	Are they near the main entrance?		NO
1.3	Is there adequate marking of parking places (vertical signpost)?	YES	
1.4	Is there access to entrance via an unobstructed accessible route?	YES	
1.5	Is the car park area surface paved (no gravel)?	YES	
	Remarks: <ul style="list-style-type: none"> - Dimensions of parking facilities for persons with disabilities are 3.00mx5.00m and 3.30x5.00m. - The parking facilities for persons with disabilities are (away from) not close to reception, public areas and accessible friendly rooms. 		
2	Entrance		
2.1	Does the entrance door permit easy access?	YES	
2.2	Number of steps between ground level and entrance?	N/A	
2.3	Is there a supporting handrail at the staircase entrance?		NO
2.4	Is there a ramp at the entrance?	YES	
	2.4.1	Length of ramp?	10.50m
	2.4.2	Slope of ramp?	4%
	2.4.3	Is there a supporting handrail at the ramp?	NO
	2.4.4	Is the ramp floor surface non-slippery?	YES
	Remarks: <ul style="list-style-type: none"> - At the entrance there is a ramp (of) del 10,50m long, with a 3,28m width and a 4% slope. 		

3	Outdoor common use areas			
	3.1	Are there any steps in main common use outdoor areas and how many?		NO
	3.2	Can a wheelchair maneuver freely in most of the outdoor areas?	YES	
	3.3	Is there a swimming-pool?	YES	
	3.4	Is there a mechanism for hoisting persons with disabilities in/out of the swimming-pool?		NO
	3.5	Is there a restroom facility with shower(s) and changing room(s) by the outdoor swimming-pool for use by persons with disabilities?		NO
	3.6	Is there adequate access to the beach for persons with disabilities?		NO
	3.7	Does the unit provide appropriate wheelchairs for use on the beach?		NO
	3.8	Does the unit provide appropriate wheelchairs for use in seawater?		NO
Remarks: <ul style="list-style-type: none"> - There is a ramp of (2,73m. + 6,75m. long)? with (landing) a 1,80m landing, from the lobby to the swimming pool and apartment blocks. - Each block of flats has a ramp of a 2.5% slope. - The shower of the swimming pool has a step of 0.09m. From the swimming pool to the shower there is an additional step of 0.13m. 				
4	Indoor common areas			
	4.1	Are there indoor elevated areas?		NO
	4.1.1	Number of steps?		N/A
	4.1.2	Provision of ramps to facilitate access between ground and elevated areas?		NO
	4.1.3	Length of ramp?		N/A
	4.1.4	Is there a supporting handrail for ramp?		N/A
	4.1.5	Slope of the ramp?		N/A
	4.2	Is there a reception area counter/desk for use by persons with disabilities (i.e. 80cm height)?		NO
	4.3	Restaurant	YES	
	4.3.1	Is there at least one height-adjustable table in dining room?		NO
	4.3.2	Height of tables in dining rooms?		0.74m
	4.3.3	Are the tables in dining rooms free from obstacles (e.g. large bases) to allow a person in a wheelchair to eat comfortably?		NO
Remarks: <ul style="list-style-type: none"> - The table base is square and does not allow wheelchair users to dine comfortably. 				
5	Common use area restroom/sanitary facilities			
	5.1	Accessible toilet booths for use by persons with disabilities?	YES	
	5.2	Dimensions (mXm) of toilet facilities?		1.98 x 1.95m

5.3	Does the toilet door open outwards?		YES	
5.4	Are there supporting handrails on either side of toilet bowl?		YES	
	5.4.1	Is there a horizontal handrail on the sidewall (if the toilet bowl is situated 50cm from the sidewall)?	YES	
	5.4.2	Is there a drop-down rail at the unobstructed side of toilet?	YES	
5.5	Wash basin			
	i	Wash basin without stand?	YES	
	ii	Adjustable height?		NO
	iii	Height of wash basin?	0.60m	
	iv	Is there an unobstructed access below wash basin for wheelchair users?		NO
Remarks: <ul style="list-style-type: none"> - There are 2 common area restrooms for use by persons with disabilities (1 in the main building and one in Robinson's restaurant). - The Robinson's accessible toilet booth has dimensions of 2.50mx3.70m and is equipped with handles. - The door of the common area restroom/sanitary facilities is 0.95m wide and opens outwards. 				
6	Lifts/Elevators			
6.1	Dimensions (mXm) of lift?		N/A	
6.2	Width (cm) of lift entrance with door(s) open?		N/A	
Remarks:				
7	Is the corridor to the rooms/apartments carpeted?			NO
Remarks:				
8	Rooms/ apartments for people with special access needs –Specify actual Door No(s): 228			
8.1	Number of rooms/ apartments for use by persons with disabilities		2	
8.2	Does the entrance to room/ apartment have a minimum unobstructed width of 85cm?		YES	
8.3	Is the entrance door easy to open?		YES	
8.4	Width of room/ apartment anteroom		1.20m	
8.5	Is the floor of the bedroom/ apartment carpeted?			NO
8.6	Is there sufficient unobstructed wheelchair turning / maneuvering space (minimum 1.5X1.5 m) in the room?		YES	
8.7	Are there audible emergency alarms?		YES	
8.8	Are there visible emergency alarms?			NO

8.9	Is the room's/ apartment's closet at a suitable height for use by persons with disabilities?			NO
8.10	Is there unobstructed non-elevated balcony access for wheelchair use?		YES	
8.11	Is there elevated difference with the balcony? NO		Height? 0,84m	
8.12	Room/ apartment restroom/sanitary facilities			
	8.12.1	Entry door width?	0.94m	
	8.12.2	Does the entry door open outwards / or does it slide?		NO
	8.12.3	Is there a horizontal door shutting bar mounted to the inside surface of the entry door?		NO
	8.12.4	Dimensions (mXm) of restroom?	2.10 x 1.60m	
	8.12.5	Is there unobstructed space of minimum 80cm width by the side of toilet bowl for easy transfer from wheelchair?		NO
	8.12.6	Is there an emergency alarm pull cord?		NO
	8.12.7	Distance from toilet bowl to nearest sidewall?	0.50m	
	8.12.8	Grab handling rails		
		i	Is there a mounted horizontal handrail on the sidewall (if the toilet bowl is situated 50cm from the sidewall)?	YES
		ii	Is there a drop-down rail at the unobstructed approach side of the toilet bowl?	YES
		iii	Where the distance of the toilet bowl from the sidewall is greater than 50cm, is there a second drop-down rail?	N/A
	8.12.9	Wash basin		
		i	Wash basin without stand?	YES
		ii	Adjustable height?	NO
		iii	Height of wash basin?	0.65m
		iv	Is there an unobstructed access below wash basin for wheelchair users?	YES
		v	Is there an easy to reach mixer/water tap?	YES
	8.12.10	Shower/ Bathtub		
		i	Is the shower floor at the same level as the floor?	NO
		ii	Is there a drop-down seat in the shower? If the above answer is YES: Is the height adjustable? NO Height? 0.48m	NO
		iii	Is there any other type of seat for people who cannot stand?	NO
			If YES, is the height adjustable? NO	Height? N/A
		iv	Are there any shower grab rails?	YES
		v	Is there a bathtub?	NO
		vi	Does the unit provide appropriate adjustable seats for use in the bathtub?	NO
		vii	Are there any grab-rails in the bathtub?	N/A

		viii	Is there provision for a bath wheelchair upon request?		NO
		ix	Is there a hoist mechanism on the ceiling?		NO
Remarks: <ul style="list-style-type: none"> - The apartment entrance door is 0.95m wide. - (The) del Opening of the balcony door is difficult. Assistance by an accompanying person is necessary. - The apartment restroom/sanitary facilities door opens inwards. - Between the shower and floor, there is a step of 0.04m. - The (room) bedroom closet has a hanging rail at a height of 1.67m. 					
General comments:					