



<b>(A) GENERAL SITE/BUILDING INFORMATION</b>			
<b>ITEM#</b>	<b>PROVISION DESCRIPTION</b>	<b>CHECKLIST</b>	<b>PHO#</b>
A.01	Number of Floors	2 (Only GF Accessible)	P.01
A.02	Receptionist	No	
A.03	Qualified Singer / Languages Spoken	No	
A.04	Site Access	Vehicle	
A.05	Parking Area Access	Free	
A.06	Drop Off Point	Yes	P.02
A.07	Onsite Disabled Parking Spaces (3.30x5.00m)	N/A	P.03
A.08	Onsite Wheelchair-Accessible Vehicle Parking	N/A	P.04
A.09	On-Street Disabled Parking (2.70x5.00m)	N/A	P.05
A.10	Access Ramps	Yes (More info in part D)	P.06
A.11	Lifting Platforms	No	P.07
A.12	Disabled Bathrooms (Number/ Int Dimensions)	2 / 2.00m x 200m	P.08
A.13	Disabled Bathrooms (Door width/Threshold Height)	≥90cm	
A.14	Disabled Elevators	N/A (More info in part C)	P.09
A.15	Tactile Site/Building Guidance	N/A (More info in part G)	
A.16	Braille Writing System Signage/Tactile Diagrams	N/A (More info in part H)	
A.17	Hearing/Speech Impaired Communication Syst.	N/A (More info in part F)	
A.18	Emergency Alerting Systems	Yes (Audible)	
A.19	Staircase Disabled Emergency Waiting Point	No	
A.20	Surface Materials – Parking Area	Asphalt	P.10
A.21	Surface Materials – Entrance	Marble	P.11
A.22	Surface Materials – Reception/Lobby	N/A	P.12
A.23	Surface Materials – Corridors	Marble	P.13
A.24	Surface Materials – Other Indoor Spaces	Tiles/Marble	P.14.1-2
A.25	Surface Materials – Outdoor Gathering Spaces	Marble	P.15
A.26	Main Entry Vestibule	No (More info in part B)	
A.27	Main Entry Door Operation	Handrails	P.16
A.28	Main Entry Door Type/ Single Door Width	Double/Wood/≥90cm	
A.29	Main Entry Door Opening Direction	Outwards	
A.30	Main Entry Door Threshold Height	N/A	
A.31	Wheelchair Accessible Entrance	N/A (More info in part B)	P.17
A.32	Interior Doors (single door min/max width)	≥90cm	
A.33	Corridor Width (min/max width)	1.00m/2.10m	
A.34	Corridor Widening Point (≥1.80x1.80m)	No	
A.35	Drain Covers Types	N/A (See Photos)	P.18
A.36	Indoor Light Intensity(LUX)	INA	
A.37	Outdoor Light Intensity (LUX)	INA	



<b>(B) SITE/BUILDING SPECIAL REQUIREMENTS INFORMATION</b>			
<b>ITEM#</b>	<b>PROVISION DESCRIPTION</b>	<b>CHECKLIST</b>	<b>PHO#</b>
B.01	Special Category Type Site/Building	Listed Building	
B.02	Wheelchair Accessible Entrance (Door Operation)	N/A	P.16
B.03	WCA Entrance (Door Type/Single Door Width)	N/A	P.16
B.04	WCA Entrance (Door Opening Direction)	N/A	P.16
B.05	WCA Entrance (Threshold Height)	N/A	P.16
B.06	Service Counter Height/Knee Space (70cm/60cm)	N/A	P.19
B.07	Service Counter Area (r ≥1.50m) or Dimensions	N/A	
B.08	Wheelchair Spaces Available	N/A	P.20
B.09	Wheelchair Spaces (Row Location)	N/A	
B.10	Theater Stage/Playing Field Disabled Access	No	
B.11	Church Iconostasi Access	No	
B.12	Vestibule Dimensions (L x W)	N/A	
B.13	Vestibule Interior Door Operation	N/A	
B.14	Vestibule Interior Door (Type/ Single Door Width)	N/A	
B.15	Vestibule Interior Door Opening Direction	N/A	
B.16	Playground Accessibility	No	P.21
B.17	Special Needs Playground Equipment	No	P.22
B.18	Inclusive Site/Building Furnishings	No	P.23
B.19	Bathroom 1 <sup>st</sup> Door Width	1.00m	P.24

<b>(C) ELEVATOR INFORMATION</b>			
<b>ITEM#</b>	<b>PROVISION DESCRIPTION</b>	<b>CHECKLIST</b>	<b>PHO#</b>
C.01	Elevators for Disabled	1	P.09
C.02	Floor Announcement System	Yes	
C.03	Control Panel with Tactile Numbers & Braille	Yes	
C.04	Warning Floor Strip	Yes	
C.05	Waiting Area (Door - Wall Distance ≥150cm)	Yes	
C.06	Door - Frame Color Contrast	High/Medium/Low	P.09
C.07	Door Width ≥90cm	Yes	
C.08	Elevator Cabin Dimensions (≥110 x 140cm)	Yes	
C.09	Elevator Cabin Dimensions (≥110 x 220cm)	Yes	
C.10	Wall Mirror Inside Cabin	Yes	
C.11	Cabin Handrails	Yes	
C.12	Cabin Control Panel (Tactile Numbers/Braille)	Yes	
C.13	Cabin Announcement System	Yes (Language)	
C.14	Cabin Anti-Slip, non-Reflective Floor	Yes	
C.15	Cabin Emergency Communication System	Yes	
C.16	Waiting Area Light Intensity (200 LUX)	INA	



<b>(D) ACCESS RAMPS DETAILS – RAMP #01 (≥ 5%)</b>			
<b>ITEM#</b>	<b>PROVISION DESCRIPTION</b>	<b>CHECKLIST</b>	<b>PHO#</b>
D.01	Access Ramp Location	Entrance	P.06
D.02	Rain Protection System	No	
D.03	Number of Inclined Planes	1	
D.04	Number of intermediate Level Landings	0	
D.05	Top Landing Dimensions (Length x Width)	≥1.50m x 1.20m	
D.06	Top Landing Tactile Warning Strip	No	
D.07	Inclined Plane (Slope-Length x Width)	6% - 3.70m x 1.70m	
D.08	Inclined Plane Handrails information	One Side	
D.09	Inclined Plane Handrails Height (70cm & 90cm)	90cm	
D.10	Inclined Plane - Width between Handrails	N/A	
D.11	Inclined Plane Edge Protection	No	
D.12	Bottom Landing Dimensions (Length x Width)	≥1.50m x 1.20m	
D.13	Bottom Landing Tactile Warning Strip	No	

<b>(D) ACCESS RAMPS DETAILS – RAMP #02 (≥ 5%)</b>			
<b>ITEM#</b>	<b>PROVISION DESCRIPTION</b>	<b>CHECKLIST</b>	<b>PHO#</b>
D.01	Access Ramp Location	Entrance/Indoor/Outdoor	P.06.4-6
D.02	Rain Protection System	Yes/No/Indoor	
D.03	Number of Inclined Planes	2	
D.04	Number of intermediate Level Landings	1	
D.05	Top Landing Dimensions (Length x Width)	≥1.50m x 1.20m	
D.06	Top Landing Tactile Warning Strip	No	
D.07	1 <sup>st</sup> Inclined Plane (Slope-Length x Width)	5% - 10.0m x 1.20m	
D.08	1 <sup>st</sup> Inclined Plane Handrails information	Both Sides/One Side/No	
D.09	1 <sup>st</sup> Inclined Pln Handrails Height (70cm & 90cm)	70cm & 90cm	
D.10	1 <sup>st</sup> Inclined Plane - Width between Handrails	1.00m	
D.11	1 <sup>st</sup> Inclined Plane Edge Protection	Yes	
D.12	1 <sup>st</sup> intermediate Level Landing (Length x Width)	1.50m x 1.20m	
D.13	1 <sup>st</sup> Landing Handrails information	Both Sides/One Side/No	
D.14	1 <sup>st</sup> Landing Edge Protection	Yes	
D.15	2 <sup>nd</sup> Inclined Plane (Slope-Length x Width)	5% - 10.0m x 1.20m	
D.16	2 <sup>nd</sup> Inclined Plane Handrails information	Both Sides/One Side/No	
D.17	2 <sup>nd</sup> Inclined Pln Handrails Height (70cm & 90cm)	70cm & 90cm	
D.18	2 <sup>nd</sup> Inclined Plane - Width between Handrails	1.00m	
D.19	2 <sup>nd</sup> Inclined Plane Edge Protection	Yes	
D.20	Bottom Landing Dimensions (Length x Width)	1.50m x 1.20m	
D.21	Bottom Landing Tactile Warning Strip	No	



<b>(D) ACCESS RAMPS DETAILS – RAMP #03 (&lt; 5%)</b>			
<b>ITEM#</b>	<b>PROVISION DESCRIPTION</b>	<b>CHECKLIST</b>	<b>PHO#</b>
D.01	Access Ramp Location	Entrance/Indoor/Outdoor	P.06.1-3
D.02	Rain Protection System	Yes/No/Indoor	
D.03	Number of Inclined Planes	1	
D.04	Number of intermediate Level Landings	0	
D.05	Top Landing Dimensions (Length x Width)	≥1.50m x 1.20m	
D.06	Inclined Plane (Slope-Length x Width)	4.5% - 10.0m x 1.20m	

**(E) SIGNAGE INFORMATION**

<b>ITEM#</b>	<b>AREA – SIGNAGE PROVISION</b>	<b>CHECKLIST</b>	<b>PHO#</b>
E.01	Site/Building – Address Number	No	
E.02	Site/Building – Site/Building Name	Yes	P.01
E.03	Parking – Disabled Parking Space Symbol	No	
E.04	Parking – International Accessibility Symbol	No	
E.05	Parking – Building Access Ramp Location	No	
E.06	Parking – Site Diagram	No	
E.07	Parking – Directional	No	
E.08	Parking – General Information	No	
E.09	Entrance/Reception – Site/Building Diagram	No	
E.10	Entrance/Reception – Directional	No	
E.11	Entrance/Reception – Bathroom Location	No	
E.12	Entrance/Reception – General Information	No	
E.13	Inside Facility – Exhibition Area Labels	N/A	P.25
E.14	Inside Facility – Site/Building Diagram	No	
E.15	Inside Facility – Directional	No	
E.16	Inside Facility – Bathroom Location	No	
E.17	Inside Facility – Emergency Exit	Yes (Luminus)	
E.18	Facility’s Outdoor Area – Site/Building Diagram	No	
E.19	Facility’s Outdoor Area – Directional	No	
E.20	Other(Description)	No	

**(F) HEARING & SPEECH IMPAIRED INFORMATION**

ITEM#	AREA – PROVISION DESCRIPTION	CHECKLIST	PHO#
F.01	Qualified Signer	No	
F.02	Sign Languages Spoken	CY, GR, EN, No	
F.03	Reception Design Specific Space	No	
F.04	Visual Emergency Alerting Systems	No	
F.05	Augmenting Systems – ex. Induction Loop	No	
F.06	Augmenting Systems –ex. Fm	No	
F.07	Transforming Systems – ex. Captioned Phone	No	
F.08	Transparent Masks for Covid-19	No	

**(G) VISUALLY IMPAIRED INFORMATION – TACTILE GUIDANCE**

ITEM#	TACTILE PROVISION (FROM – TO)	CHECKLIST	PHO#
G.01	Public Sidewalk to Parking Area	No	
G.02	Public Sidewalk to Entrance	No	
G.03	Parking Area to Entrance	No	
G.04	Reception to Bathrooms	No	
G.05	Reception to other Interior Areas	No	
G.06	Interior Areas to Emergency Exit	No	
G.07	Interior Areas to Outdoor Spaces	No	

**(H) VISUALLY IMPAIRED INFORMATION – BRAILLE SYSTEM & TACTILE DIAGRAMS**

ITEM#	BRAILLE & TACTILE DIAGRAM PROVISION	CHECKLIST	PHO#
H.01	Parking Area – Tactile Site Diagram	No	
H.02	Parking Area – General information in Braille	No	
H.03	Entrance/Reception – Tactile Site Diagram	No	
H.04	Entrance/Reception – Tactile Building Diagram	No	
H.05	Entrance/Recep. – General information in Braille	No	
H.06	Inside Facility – Room Info & Number in Braille	No	
H.07	Room Info & Number Location in Braille	Door Handle Side	
H.08	Outdoor Areas – Tactile Site/Building Diagram	No	
H.09	Outdoor Areas – General Information in Braille	No	