



| <b>(A) GENERAL SITE/BUILDING INFORMATION</b> |   |   |             |
|--|---|---|-------------|
| <b>ITEM#</b>                                 | <b>PROVISION DESCRIPTION</b>                    | <b>CHECKLIST</b>  | <b>PHO#</b> |
| A.01   | Number of Floors                                | 5-(GF, 1 <sup>st</sup> , 2 <sup>nd</sup> , -1, -2, Access.) | P.01.1-2    |
| A.02   | Receptionist                                    | Yes   |             |
| A.03   | Qualified Singer / Languages Spoken             | No  |             |
| A.04   | Site Access                                     | Vehicle   |             |
| A.05   | Parking Area Access                             | Free  |             |
| A.06   | Drop Off Point                                  | Yes( No Designated Area                                     | P.02        |
| A.07   | Onsite Disabled Parking Spaces (3.30x5.00m)     | 16- (3.70X4.80m)  | P.03        |
| A.08   | Onsite Wheelchair-Accessible Vehicle Parking    | No  | P.04        |
| A.09   | On-Street Disabled Parking (2.70x5.00m)         | No  | P.05        |
| A.10   | Access Ramps                                    | Yes (More info in part D)                                   | P.06        |
| A.11   | Lifting Platforms                               | No  | P.07        |
| A.12   | Disabled Bathrooms-Dimensions/ Door width       | 12- (2.00x1.60m)/ 81cm/84cm                                 | P.08.1-3    |
| A.13   | Disabled Elevators                              | Yes (More info in part C)                                   | P.09.1-2    |
| A.14   | Tactile Site/Building Guidance                  | No (More info in part G)                                    |             |
| A.15   | Braille Writing System Signage/Tactile Diagrams | No (More info in part H)                                    |             |
| A.16   | Hearing/Speech Impaired Communication Syst.     | No (More info in part F)                                    |             |
| A.17   | Emergency Alerting Systems                      | Yes(Audible)  |             |
| A.18   | Staircase Disabled Emergency Waiting Point      | No  |             |
| A.19   | Surface Materials – Parking Area                | Asphalt   | P.10        |
| A.20   | Surface Materials – Entrance                    | Concrete Blocks   | P.11        |
| A.21   | Surface Materials – Reception/Lobby             | Industrial Floor  | P.12        |
| A.22   | Surface Materials – Corridors                   | Ceramic Tiles / Industrial                                  | P.13        |
| A.23   | Surface Materials – Other Indoor Spaces         | Carpet/ Cer. Tiles/ Industrial                              | P.14        |
| A.24   | Surface Materials – Outdoor Gathering Spaces    | Concrete Blocks   | P.15        |
| A.25   | Main Entry Vestibule                            | No(More info in part B)                                     |             |
| A.26   | Main Entry Door Operation                       | Panic Bar   |             |
| A.27   | Main Entry Door Type/ Single Door Width         | Double/Opaque/≥90cm   |             |
| A.28   | Main Entry Door Opening Direction               | Outwards/Right  |             |
| A.29   | Main Entry Door Threshold Height                | ≤10mm   |             |
| A.30   | Interior Doors Width (min/max width)            | 82cm/≥90cm  |             |
| A.31   | Corridor Width (min/max width)                  | 0.90m/4.45m   |             |
| A.32   | Corridor Widening Point (≥1.80x1.80m)           | No  |             |
| A.33   | Drain Covers Types                              | Yes (See Photos)  | P.16        |
| A.34   | Indoor Light Intensity(LUX)                     | INA   |             |
| A.35   | Outdoor Light Intensity (LUX)                   | INA   |             |



| <b>(B) SITE/BUILDING SPECIAL REQUIREMENTS INFORMATION</b> |   |                    |             |
|---|---|--------------------|-------------|
| <b>ITEM#</b>  | <b>PROVISION DESCRIPTION</b>                    | <b>CHECKLIST</b>   | <b>PHO#</b> |
| B.01  | Special Category Type Site/Building             | Sports Facilities  |             |
| B.02  | Ticket Counter Height/Knee Space (70cm/60cm)    | 95cm               |             |
| B.03  | Ticket Counter Area (r ≥1.50m) or Dimensions    | 1.00 x 0.75m       | P.17        |
| B.04  | Arena Wheelchair Spaces Available               | Level 0 / 24       | P.18        |
| B.05  | Arena Wheelchair Spaces (Row Location)          | No                 |             |
| B.06  | Arena Stage/Playing Field Disabled Access       | Yes/Accessible     |             |
| B.07  | Church Iconostasi Access                        | N/A                |             |
| B.08  | Vestibule Dimensions (L x W)                    | N/A                |             |
| B.09  | Vestibule Interior Door Operation               | N/A                |             |
| B.10  | Vestibule Interior Door Type/ Single Door Width | N/A                |             |
| B.11  | Vestibule Interior Door Opening Direction       | N/A                |             |
| B.12  | Playground Accessibility                        | N/A                | P.19        |
| B.13  | Special Needs Playground Equipment              | N/A                | P.20        |
| B.14  | Inclusive Site/Building Furnishings             | No                 | P.21        |
| B.15  | Food-Drinks Sale/Retail Sale Counters Heights   | 0.80m              | P.22        |
| B.16  | Customer Area Space Available (min/max width)   | 0.75 / 1.00        |             |
| B.17  | Ticket Entry Door Type/ Single Door Width       | Single/Opaque/65cm | P.23        |
| B.18  | Information Counter Height/Knee Space           | 120cm              | P.24        |
| B.19  | Information Counter Area (r ≥1.50m)             | ≥1.50m             |             |
| B.20  | Electronic Media Counter Height/Knee Space      | 70cm/75cm          | P.25        |
| B.21  | Invited Guests Rec. Counter Height/Knee Space   | 120cm              | P.26        |
| B.22  | Cloakroom Counter Height/Knee Space             | 115cm              | P.27        |
| B.23  | Cloakroom Counter Area Dimensions               | 1.00m x 1.00m      |             |
| B.24  | Spectators Sports Halls Disabled Access         | Yes/Accessible     | P.28.1-7    |
| B.25  | Dressing Rooms Disabled Access                  | Yes/Accessible     | P.29        |
| B.26  | Shower Rooms Wheelchair Ac./ Threshold Height   | No Access /10cm    | P.30.1-2    |
| B.27  | Sink Counter Height/Knee Space (70cm/60cm)      | 90cm/60cm          | P.31        |
| B.28  | Sink Counter Area (r ≥1.50m) or Dimensions      | ≥1.50m             |             |



| <b>(C) ELEVATOR INFORMATION</b> |   |                  |             |
|---------------------------------|---|------------------|-------------|
| <b>ITEM#</b>                    | <b>PROVISION DESCRIPTION</b>                  | <b>CHECKLIST</b> | <b>PHO#</b> |
| C.01                            | Elevators for Disabled                        | 1                | P.09.1-2    |
| C.02                            | Floor Announcement System                     | No               |             |
| C.03                            | Control Panel with Tactile Numbers & Braille  | Partial          |             |
| C.04                            | Warning Floor Strip                           | No               |             |
| C.05                            | Waiting Area (Door – Wall Distance) ≥150cm    | Yes              |             |
| C.06                            | Door - Frame Color Contrast                   | Medium           | P.09.1-2    |
| C.07                            | Door Width ≥90cm                              | Yes              |             |
| C.08                            | Elevator Cabin Dimensions ≥110 x 140cm        | No               |             |
| C.09                            | Elevator Cabin Dimensions ≥110 x 220cm        | Yes              |             |
| C.10                            | Wall Mirror Inside Cabin                      | No               |             |
| C.11                            | Cabin Handrails                               | Yes              |             |
| C.12                            | Cabin Control Panel (Tactile Numbers/Braille) | No               |             |
| C.13                            | Cabin Announcement System                     | No               |             |
| C.14                            | Cabin Anti-Slip, non-Reflective Floor         | Yes              |             |
| C.15                            | Cabin Emergency Communication System          | Yes              |             |
| C.16                            | Waiting Area Light Intensity (200 LUX)        | INA              |             |

| <b>(C) ELEVATOR INFORMATION</b> |   |                  |             |
|---------------------------------|---|------------------|-------------|
| <b>ITEM#</b>                    | <b>PROVISION DESCRIPTION</b>                  | <b>CHECKLIST</b> | <b>PHO#</b> |
| C.01                            | Elevators for Disabled                        | 1                | P.09.1-2    |
| C.02                            | Floor Announcement System                     | No               |             |
| C.03                            | Control Panel with Tactile Numbers & Braille  | Yes              |             |
| C.04                            | Warning Floor Strip                           | No               |             |
| C.05                            | Waiting Area (Door – Wall Distance) ≥150cm    | Yes              |             |
| C.06                            | Door - Frame Color Contrast                   | Medium           | P.09.1-2    |
| C.07                            | Door Width ≥90cm                              | Yes              |             |
| C.08                            | Elevator Cabin Dimensions ≥110 x 140cm        | Yes              |             |
| C.09                            | Elevator Cabin Dimensions ≥110 x 220cm        | No               |             |
| C.10                            | Wall Mirror Inside Cabin                      | No               |             |
| C.11                            | Cabin Handrails                               | Yes              |             |
| C.12                            | Cabin Control Panel (Tactile Numbers/Braille) | Yes              |             |
| C.13                            | Cabin Announcement System                     | No               |             |
| C.14                            | Cabin Anti-Slip, non-Reflective Floor         | Yes              |             |
| C.15                            | Cabin Emergency Communication System          | Yes              |             |
| C.16                            | Waiting Area Light Intensity (200 LUX)        | INA              |             |

| <b>(D)ACCESS RAMPS DETAILS – RAMP #01 (≥5%)</b> |   |                          |             |
|---|---|--------------------------|-------------|
| <b>ITEM#</b>                                    | <b>PROVISION DESCRIPTION</b>                  | <b>CHECKLIST</b>         | <b>PHO#</b> |
| D.01  | Access Ramp Location                          | Indoor/ Food-Drinks Sale | P.06.1-3    |
| D.02  | Rain Protection System                        | Yes                      |             |
| D.03  | Number of Inclined Planes                     | 1                        |             |
| D.04  | Number of intermediate Level Landings         | 0                        |             |
| D.05  | Top Landing Dimensions (Length x Width)       | ≥1.50m x 1.50m           |             |
| D.06  | Top Landing Tactile Warning Strip             | No                       |             |
| D.07  | Inclined Plane (Slope-Length x Width)         | 10% - 7.00m x 1.45m      |             |
| D.08  | Inclined Plane Handrails information          | No Handrails             |             |
| D.09  | Inclined Plane Handrails Height (70cm & 90cm) | N/A                      |             |
| D.10  | Inclined Plane - Width between Handrails      | N/A                      |             |
| D.11  | Inclined Plane Edge Protection                | Yes                      |             |
| D.12  | Bottom Landing Dimensions (Length x Width)    | ≥1.50m x 1.50m           |             |
| D.13  | Bottom Landing Tactile Warning Strip          | No                       |             |

| <b>(D)ACCESS RAMPS DETAILS – RAMP #02 (≥5%)</b> |   |                         |             |
|---|---|-------------------------|-------------|
| <b>ITEM#</b>                                    | <b>PROVISION DESCRIPTION</b>                                | <b>CHECKLIST</b>        | <b>PHO#</b> |
| D.01  | Access Ramp Location  | Entrance/Indoor/Outdoor | P.06.4-6    |
| D.02  | Rain Protection System                                      | Yes/No/Indoor           |             |
| D.03  | Number of Inclined Planes                                   | 2                       |             |
| D.04  | Number of intermediate Level Landings                       | 1                       |             |
| D.05  | Top Landing Dimensions (Length x Width)                     | ≥1.50m x 1.20m          |             |
| D.06  | Top Landing Tactile Warning Strip                           | No                      |             |
| D.07  | 1 <sup>st</sup> Inclined Plane (Slope-Length x Width)       | 5%-10.0m x 1.20m        |             |
| D.08  | 1 <sup>st</sup> Inclined Plane Handrails information        | Both Sides/One Side/No  |             |
| D.09  | 1 <sup>st</sup> Inclined PlnHandrails Height (70cm & 90cm)  | 70cm & 90cm             |             |
| D.10  | 1 <sup>st</sup> Inclined Plane - Width between Handrails    | 1.00m                   |             |
| D.11  | 1 <sup>st</sup> Inclined Plane Edge Protection              | Yes                     |             |
| D.12  | 1 <sup>st</sup> intermediate Level Landing (Length x Width) | 1.50m x 1.20m           |             |
| D.13  | 1 <sup>st</sup> Landing Handrails information               | Both Sides/One Side/No  |             |
| D.14  | 1 <sup>st</sup> Landing Edge Protection                     | Yes                     |             |
| D.15  | 2 <sup>nd</sup> Inclined Plane (Slope-Length x Width)       | 5% - 10.0m x 1.20m      |             |
| D.16  | 2 <sup>nd</sup> Inclined Plane Handrails information        | Both Sides/One Side/No  |             |
| D.17  | 2 <sup>nd</sup> Inclined Pln Handrails Height (70cm & 90cm) | 70cm & 90cm             |             |
| D.18  | 2 <sup>nd</sup> Inclined Plane - Width between Handrails    | 1.00m                   |             |
| D.19  | 2 <sup>nd</sup> Inclined Plane Edge Protection              | Yes                     |             |
| D.20  | Bottom Landing Dimensions (Length x Width)                  | 1.50m x 1.20m           |             |
| D.21  | Bottom Landing Tactile Warning Strip                        | No                      |             |



| <b>(D) ACCESS RAMPS DETAILS – RAMP #03 (&lt;5%)</b> |   |                         |             |
|---|---|-------------------------|-------------|
| <b>ITEM#</b>  | <b>PROVISION DESCRIPTION</b>            | <b>CHECKLIST</b>        | <b>PHO#</b> |
| D.01  | Access Ramp Location                    | Entrance/Indoor/Outdoor | P.06.1-3    |
| D.02  | Rain Protection System                  | Yes/No/Indoor           |             |
| D.03  | Number of Inclined Planes               | 1                       |             |
| D.04  | Number of intermediate Level Landings   | 0                       |             |
| D.05  | Top Landing Dimensions (Length x Width) | ≥1.50m x 1.20m          |             |
| D.06  | Inclined Plane (Slope-Length x Width)   | 4.5% - 10.0m x 1.20m    |             |

| <b>(E) SIGNAGE INFORMATION</b> |                                |                  |             |
|--------------------------------|--------------------------------|------------------|-------------|
| <b>ITEM#</b>                   | <b>AREA –SIGNAGE PROVISION</b> | <b>CHECKLIST</b> | <b>PHO#</b> |



|      |   |               |      |
|------|---|---------------|------|
| E.01 | Site/Building – Address Number                  | No            |      |
| E.02 | Site/Building – Site/Building Name              | Yes           | P.01 |
| E.03 | Parking – Disabled Parking Space Symbol         | Yes           |      |
| E.04 | Parking – International Accessibility Symbol    | No            |      |
| E.05 | Parking – Building Access Ramp Location         | No            |      |
| E.06 | Parking – Site Diagram                          | No            |      |
| E.07 | Parking – Directional                           | No            |      |
| E.08 | Parking – General Information                   | No            |      |
| E.09 | Entrance/Reception – Site/Building Diagram      | Yes           |      |
| E.10 | Entrance/Reception – Directional                | Partial       |      |
| E.11 | Entrance/Reception – Bathroom Location          | No            |      |
| E.12 | Entrance/Reception – General Information        | Yes           |      |
| E.13 | Inside Facility – Exhibition Area Labels        | N/A           | P.24 |
| E.14 | Inside Facility – Site/Building Diagram         | Yes           |      |
| E.15 | Inside Facility – Directional                   | Partial       |      |
| E.16 | Inside Facility – Bathroom Location             | Yes           |      |
| E.17 | Inside Facility – Emergency Exit                | Yes (Luminus) |      |
| E.18 | Facility’s Outdoor Area – Site/Building Diagram | No            |      |
| E.19 | Facility’s Outdoor Area – Directional           | No            |      |
| E.20 | Other(Description)                              | No            |      |



| ITEM# | AREA – PROVISION DESCRIPTION               | CHECKLIST      | PHO# |
|-------|--|----------------|------|
| F.01  | Qualified Signer                           | No             |      |
| F.02  | Sign Languages Spoken                      | CY, GR, EN, No |      |
| F.03  | Reception Design Specific Space            | No             |      |
| F.04  | Visual Emergency Alerting Systems          | No             |      |
| F.05  | Augmenting Systems – ex. Induction Loop    | No             |      |
| F.06  | Augmenting Systems –ex. Fm                 | No             |      |
| F.07  | Transforming Systems – ex. Captioned Phone | No             |      |
| F.08  | Transparent Masks for Covid-19             | No             |      |

**(G) VISUALLY IMPAIRED INFORMATION – TACTILE GUIDANCE**

| ITEM# | TACTILE PROVISION (FROM – TO)     | CHECKLIST | PHO# |
|-------|-----------------------------------|-----------|------|
| G.01  | Public Sidewalk to Parking Area   | No        |      |
| G.02  | Public Side to Entrance           | No        |      |
| G.03  | Parking Area to Entrance          | No        |      |
| G.04  | Reception to Bathrooms            | No        |      |
| G.05  | Reception to other Interior Areas | No        |      |
| G.06  | Interior Areas to Emergency Exit  | No        |      |
| G.07  | Interior Areas to Outdoor Spaces  | No        |      |

**(H) VISUALLY IMPAIRED INFORMATION – BRAILLE SYSTEM & TACTILE DIAGRAMS**

| ITEM# | BRAILLE & TACTILE DIAGRAM PROVISION              | CHECKLIST        | PHO# |
|-------|--|------------------|------|
| H.01  | Parking Area – Tactile Site Diagram              | No               |      |
| H.02  | Parking Area – General information in Braille    | No               |      |
| H.03  | Entrance/Reception – Tactile Site Diagram        | No               |      |
| H.04  | Entrance/Reception – Tactile Building Diagram    | No               |      |
| H.05  | Entrance/Recep. – General information in Braille | No               |      |
| H.06  | Inside Facility – Room Info & Number in Braille  | No               |      |
| H.07  | Room Info & Number Location in Braille           | Door Handle Side |      |
| H.08  | Outdoor Areas – Tactile Site/Building Diagram    | No               |      |
| H.09  | Outdoor Areas – General Information in Braille   | No               |      |



| <b>LEGEND</b> |                     |                               |
|---------------|---------------------|-------------------------------|
| <b>ITEM#</b>  | <b>ABBREVIATION</b> | <b>MEANING</b>                |
| 01            | CY                  | Cypriot Dialect Sign Language |
| 02            | EN                  | English Sign Language         |
| 03            | GR                  | Greek Sign Language           |
| 04            | TG                  | Tactile Guidance              |
| 05            | INA                 | Information Not Available     |
| 06            | N/A                 | Not Applicable                |
| 07            | OSS                 | Out of Specifications         |
| 08            | r                   | Radius                        |
| 09            | d                   | Dimensions                    |
| 10            | (L x W)             | Length X Width                |
| 11            | V                   | Vehicle Access                |
| 12            | BF                  | Basement Floor                |
| 13            | GF                  | Ground Floor                  |
| 14            | 1 <sup>st</sup>     | 1 <sup>st</sup> Floor         |
| 15            | 2 <sup>nd</sup>     | 2 <sup>nd</sup> Floor         |
| 16            | MF                  | Mezzanine Floor               |
| 17            | WCA                 | Wheelchair Accessible         |