

NO TRAIL WITH THE NAME AND FEATURES GIVEN – (more info in Part B)

(A) GENERAL SITE/BUILDING INFORMATION			
ITEM#	PROVISION DESCRIPTION	CHECKLIST	PHO#
A.01	Natural Features	Disabled Nature Trail	P.01
A.02	Receptionist	No	
A.03	Qualified Singer / Languages Spoken	No	
A.04	Site Access	Vehicle	
A.05	Parking Area Access	Free	
A.06	Drop Off Point	Yes	P.02
A.07	Onsite Disabled Parking Spaces (3.30x5.00m)	No	P.03
A.08	Onsite Wheelchair-Accessible Vehicle Parking	No	P.04
A.09	On-Street Disabled Parking (2.70x5.00m)	2- Yes (2.70m x 5.00m)	P.05
A.10	Access Ramps	Yes (More info in part D)	P.06.1-8
A.11	Lifting Platforms	No	P.07
A.12	Disabled Bathrooms-Dimensions/ Door width	1-(2.00x1.70m)/ ≥90cm	P.08.1-2
A.13	Disabled Elevators	N/A	P.09
A.14	Tactile Site/Building Guidance	No (More info in part G)	
A.15	Braille Writing System Signage/Tactile Diagrams	No (More info in part H)	
A.16	Hearing/Speech Impaired Communication Syst.	No (More info in part F)	
A.17	Emergency Alerting Systems	No (Audible & Visual)	
A.18	Staircase Disabled Emergency Waiting Point	N/A	
A.19	Surface Materials – Parking Area	Concrete	P.10
A.20	Surface Materials – General Picnic Area	Earth	P.11
A.21	Surface Materials – Seating Area	Earth/Stone/Concrete Paving	P.12
A.22	Surface Materials – Water Fountain Area	Stone (More info in part B)	P.13
A.23	Surface Materials – Bar-B-Que Area	Stone (More info in part B)	P.14.1-3
A.24	Surface Materials – Playground Area	Rubber (More in part B)	P.15
A.25	Drain Covers Types	No	P.16
A.26	Indoor Light Intensity (LUX)	INA	
A.27	Outdoor Light Intensity (LUX)	INA	



(B) SITE/BUILDING SPECIAL REQUIREMENTS INFORMATION			
ITEM#	PROVISION DESCRIPTION	CHECKLIST	PHO#
B.01	Special Category Type Site/Building	Natural Site/ Picnic area	
B.02	Ticket Counter Height/Knee Space (70cm/60cm)	N/A	P.17
B.03	Ticket Counter Area (r ≥1.50m) or Dimensions	N/A	P.17
B.04	Inclusive Furnishings	Yes/ Difficult Access	P.18.1-2
B.05	Inclusive Furnishings Location	Near Entrance	
B.06	Disabled Friendly Water Fountains	No	P.13
B.07	Disabled Friendly Bar-B-Que	No	P.14
B.08	Playground Area Disabled Access	Difficult Access / Step	P.15
B.09	Special Needs Playground Equipment	No	P.19
B.10	Trash Receptacles Area Access	Accessible	P.20
B.11	Disabled Friendly Trash Receptacles	No	P.21
B.12	Recycle Receptacles Area Access	Not Available	P.22
B.13	Disabled Friendly Recycled Receptacles	No	P.23
B.14	Picnic Area Signage	Yes	P.24.1-4
B.15	Canteen Counter Height	N/A	P.25
B.16.1	Notes: 1- The forestry official on site could not inform in regards to the trail as given in the brief.	Yes	
	2- the on-site nature trail is called 'Throubiaris' is uphill into the forest, and is longer than 1km long and not circular.		P.26.1-5
	3- Another nature trail called 'kakokefalos - Mantra toy Kambiou' starts on Machairas area, is long and inaccessible		P.26.6-9
	4- For the purpose of the project's requirements, the on-site disabled trail is recorded (same as in NIC_066). It is not circular and not 1km long as described in the brief.		P.06.1-8



(C) ACCESS RAMPS DETAILS – RAMP #01 (≥5%)			
ITEM#	PROVISION DESCRIPTION	CHECKLIST	PHO#
D.01	Access Ramp Location	Disabled Trail	P.06. 6-16
D.02	Rain Protection System	No	
D.03	Number of Inclined Planes	2	
D.04	Number of intermediate Level Landings	1	
D.05	Top Landing Dimensions (Length x Width)	≥1.50m x 1.20m	
D.06	Top Landing Tactile Warning Strip	No	
D.07	1 st Inclined Plane (Slope-Length x Width)	9%- 10.00m x 1.50m	
D.08	1 st Inclined Plane Handrails information	One Side	
D.09	1 st Inclined Plane Handrails Height (70cm&90cm)	60cm & 90cm	
D.10	1 st Inclined Plane - Width between Handrails	N/A	
D.11	1 st Inclined Plane Edge Protection	No	
D.12	1 st intermediate Level Landing (Length x Width)	≥1.50m x 1.20m	
D.13	1 st Landing Handrails information	One Side	
D.14	1 st Landing Edge Protection	No	
D.15	2 nd Inclined Plane (Slope-Length x Width)	9%- 18.00m x 2.00m	
D.16	2 nd Inclined Plane Handrails information	One Side	
D.17	2 nd Inclined Plane Handrails Height	60cm & 90cm	
D.18	2 nd Inclined Plane - Width between Handrails	N/A	
D.19	2 nd Inclined Plane Edge Protection	No	
D.20	2 nd intermediate Level Landing (Length x Width)	≥1.50m x 1.20m	
D.21	2 nd Landing Handrails information	One Side	
D.22	2 nd Landing Edge Protection	No	
D.23	3 rd Inclined Plane (Slope-Length x Width)	11%- 4.00m x 2.00m	
D.24	3 rd Inclined Plane Handrails information	One Side	
D.25	3 rd Inclined Plane Handrails Height	60cm & 90cm	
D.26	3 rd Inclined Plane - Width between Handrails	N/A	
D.27	3 rd Inclined Plane Edge Protection	No	
D.28	3 rd intermediate Level Landing (Length x Width)	≥1.50m x 1.20m	
D.29	3 rd Landing Handrails information	One Side	
D.30	3 rd Landing Edge Protection	No	
D.31	4 th Inclined Plane (Slope-Length x Width)	7%- 8.10m x 1.50m	
D.32	4 th Inclined Plane Handrails information	One Side	
D.33	4 th Inclined Plane Handrails Height	60cm & 90cm	
D.34	4 th Inclined Plane - Width between Handrails	N/A	
D.35	4 th Inclined Plane Edge Protection	No	
D.36	4 th intermediate Level Landing (Length x Width)	≥1.50m x 1.20m	
D.37	4 th Landing Handrails information	One Side	



D.38	4 th Landing Edge Protection	No	
D.39	5 th Inclined Plane (Slope-Length x Width)	Various %- 50m x 1.20m	
D.30	5 th Inclined Plane Handrails information	One Side	
D.41	5 th Inclined Plane Handrails Height	60cm & 90cm	
D.42	5 th Inclined Plane - Width between Handrails	N/A	
D.43	5 th Inclined Plane Edge Protection	Yes	
D.44	5 th intermediate Level Landing (Length x Width)	≥1.50m x 1.20m	
D.45	5 th Landing Handrails information	One Side	
D.46	5 th Landing Edge Protection	No	
D.47	Bottom Landing Dimensions (Length x Width)	≥1.50m x 1.20m	
D.47	Bottom Landing Tactile Warning Strip	No	



LEGEND		
ITEM#	ABBREVIATION	MEANING
01	CY	Cypriot Dialect Sign Language
02	EN	English Sign Language
03	GR	Greek Sign Language
04	TG	Tactile Guidance
05	INA	Information Not Available
06	N/A	Not Applicable
07	OSS	Out of Specifications
08	r	Radius
09	(L x W)	Length X Width
10	V	Vehicle Access
11	BF	Basement Floor
12	GF	Ground Floor
13	1 st	1 st Floor
14	2 nd	2 nd Floor
15	MF	Mezzanine Floor