



<b>(A) GENERAL SITE/BUILDING INFORMATION</b>			
<b>ITEM#</b>	<b>PROVISION DESCRIPTION</b>	<b>CHECKLIST</b>	<b>PHO#</b>
A.01	Number of Floors	2	P.01.1-4
A.02	Receptionist	Yes	
A.03	Qualified Singer / Languages Spoken	No	
A.04	Site Access	Vehicle/Wheel Chair	
A.05	Parking Area Access	Free	
A.06	Drop Off Point	No	P.02
A.07	Onsite Disabled Parking Spaces (3.30x5.00m)	Not Designated	P.03
A.08	Onsite Wheelchair-Accessible Vehicle Parking	Not Designated	P.04
A.09	On-Street Disabled Parking (2.70x5.00m)	No	P.05
A.10	Access Ramps	Yes (More info in part D)	P.06.1-5
A.11	Lifting Platforms	No	P.07
A.12	Disabled Bathrooms (Number/ Int Dimensions)	1 / 2.00m x 2.10m	P.08
A.13	Disabled Bathrooms (Door width/Threshold Height)	≥90cm / 0cm	
A.14	Disabled Elevators	No	P.09
A.15	Tactile Site/Building Guidance	No	
A.16	Braille Writing System Signage/Tactile Diagrams	No	
A.17	Hearing/Speech Impaired Communication Syst.	No	
A.18	Emergency Alerting Systems	Yes (Audible)	
A.19	Staircase Disabled Emergency Waiting Point	No	
A.20	Surface Materials – Parking Area	Gravel	P.10
A.21	Surface Materials – Entrance	Hardwood	P.11
A.22	Surface Materials – Reception	Concrete	P.12
A.23	Surface Materials – Corridors	N/A	P.13
A.24	Surface Materials – Other Indoor Spaces	Hardwood	P.14.1-3
A.25	Surface Materials – Outdoor Gathering Spaces	Gravel/Wood/Tiles	P.15.1-4
A.26	Main Entry Vestibule	Yes (More info in part B)	
A.27	Main Entry Door Operation	Push-Pull	P.16.1-4
A.28	Main Entry Door Type/ Single Door Width	Outer:Double/Transparent/50cm Inner: Single/Opaque/1.00m	
A.29	Main Entry Door Opening Direction	Outwards/Left & Right	
A.30	Main Entry Door Threshold Height	Step	
A.31	Wheelchair Accessible Entrance	Yes (More info in part B)	P.17.1-5
A.32	Interior Doors (single door min/max width)	85cm	
A.33	Corridor Width (min/max width)	N/A	
A.34	Corridor Widening Point (≥1.80x1.80m)	No	
A.35	Drain Covers Types	Yes (See Photos)	P.18
A.36	Indoor Light Intensity(LUX)	INA	
A.37	Outdoor Light Intensity (LUX)	INA	



<b>(B) SITE/BUILDING SPECIAL REQUIREMENTS INFORMATION</b>			
<b>ITEM#</b>	<b>PROVISION DESCRIPTION</b>	<b>CHECKLIST</b>	<b>PHO#</b>
B.01	Special Category Type Site/Building	Listed/Historical Site	
B.02	Wheelchair Accessible Entrance (Door Operation)	Push-Pull	P.17.1-3
B.03	WCA Entrance (Door Type/Single Door Width)	Outer:Double/Transparent/50cm Inner: Single/Opaque/1.00m	P.16
B.04	WCA Entrance (Door Opening Direction)	Outwards/Left & Right	P.16
B.05	WCA Entrance (Threshold Height)	Ramp	P.16
B.06	Service Counter Height/Knee Space (70cm/60cm)	100cm/0cm	P.19
B.07	Service Counter Area (r ≥1.50m) or Dimensions	1.10mx2.00m	
B.08	Wheelchair Spaces Available	N/A	P.20
B.09	Wheelchair Spaces (Row Location)	N/A	
B.10	Theater Stage/Playing Field Disabled Access	N/A	
B.11	Church Iconostasi Access	N/A	
B.12	Vestibule Dimensions (L x W)	N/A	
B.13	Vestibule Interior Door Operation	N/A	
B.14	Vestibule Interior Door (Type/ Single Door Width)	N/A	
B.15	Vestibule Interior Door Opening Direction	N/A	
B.16	Playground Accessibility	N/A	P.21
B.17	Special Needs Playground Equipment	N/A	P.22
B.18	Inclusive Site/Building Furnishings	N/A	P.23
B.19	Other(Description)	Yes	
	1- Main Entry Gate (Threshold/ Single Door width)	Step 20cm/ Double 75cm	P.24.1-2
	2- WCA Entry Gate (Threshold/ Single Door width)	0cm/ Single door 1.00m	P.24.3-4

<b>(C) ELEVATOR INFORMATION</b>			
<b>ITEM#</b>	<b>PROVISION DESCRIPTION</b>	<b>CHECKLIST</b>	<b>PHO#</b>
C.01	Elevators for Disabled	1	P.09
C.02	Floor Announcement System	Yes	
C.03	Control Panel with Tactile Numbers & Braille	Yes	
C.04	Warning Floor Strip	Yes	
C.05	Waiting Area (Door - Wall Distance ≥150cm)	Yes	
C.06	Door - Frame Color Contrast	High/Medium/Low	P.09
C.07	Door Width ≥90cm	Yes	
C.08	Elevator Cabin Dimensions (≥110 x 140cm)	Yes	
C.09	Elevator Cabin Dimensions (≥110 x 220cm)	Yes	
C.10	Wall Mirror Inside Cabin	Yes	
C.11	Cabin Handrails	Yes	
C.12	Cabin Control Panel (Tactile Numbers/Braille)	Yes	
C.13	Cabin Announcement System	Yes (Language)	
C.14	Cabin Anti-Slip, non-Reflective Floor	Yes	
C.15	Cabin Emergency Communication System	Yes	
C.16	Waiting Area Light Intensity (200 LUX)	INA	

**(D) ACCESS RAMPS DETAILS – RAMP #01 (≥ 5%)**

ITEM#	PROVISION DESCRIPTION	CHECKLIST	PHO#
D.01	Access Ramp Location	Back Entrance/ Outdoor	P.06.1-2
D.02	Rain Protection System	Indoor	
D.03	Number of Inclined Planes	1	
D.04	Number of intermediate Level Landings	0	
D.05	Top Landing Dimensions (Length x Width)	50cm x 100cm	
D.06	Top Landing Tactile Warning Strip	No	
D.07	Inclined Plane (Slope-Length x Width)	11% - 2.54m x 1.20m	
D.08	Inclined Plane Handrails information	No	
D.09	Inclined Plane Handrails Height (70cm & 90cm)	N/A	
D.10	Inclined Plane - Width between Handrails	N/A	
D.11	Inclined Plane Edge Protection	N/A	
D.12	Bottom Landing Dimensions (Length x Width)	N/A	
D.13	Bottom Landing Tactile Warning Strip	N/A	

**(D) ACCESS RAMPS DETAILS – RAMP #02 (≥ 5%)**

ITEM#	PROVISION DESCRIPTION	CHECKLIST	PHO#
D.01	Access Ramp Location	Outdoor (to WC area)	P.06.
D.02	Rain Protection System	No	
D.03	Number of Inclined Planes	2	
D.04	Number of intermediate Level Landings	1	
D.05	Top Landing Dimensions (Length x Width)	0.80m x 1.60m	
D.06	Top Landing Tactile Warning Strip	No	
D.07	1 <sup>st</sup> Inclined Plane (Slope-Length x Width)	9% - 0.75m x 1.60m	
D.08	1 <sup>st</sup> Inclined Plane Handrails information	N/A	
D.09	1 <sup>st</sup> Inclined Pln Handrails Height (70cm & 90cm)	N/A	
D.10	1 <sup>st</sup> Inclined Plane - Width between Handrails	N/A	
D.11	1 <sup>st</sup> Inclined Plane Edge Protection	N/A	
D.12	1 <sup>st</sup> intermediate Level Landing (Length x Width)	N/A	
D.13	1 <sup>st</sup> Landing Handrails information	N/A	
D.14	1 <sup>st</sup> Landing Edge Protection	N/A	
D.15	2 <sup>nd</sup> Inclined Plane (Slope-Length x Width)	9% - 0.75m x 1.60m	
D.16	2 <sup>nd</sup> Inclined Plane Handrails information	No	
D.17	2 <sup>nd</sup> Inclined Pln Handrails Height (70cm & 90cm)	N/A	
D.18	2 <sup>nd</sup> Inclined Plane - Width between Handrails	N/A	
D.19	2 <sup>nd</sup> Inclined Plane Edge Protection	N/A	
D.20	Bottom Landing Dimensions (Length x Width)	N/A	
D.21	Bottom Landing Tactile Warning Strip	N/A	



<b>(D) ACCESS RAMPS DETAILS – RAMP #03 (&lt; 5%)</b>			
<b>ITEM#</b>	<b>PROVISION DESCRIPTION</b>	<b>CHECKLIST</b>	<b>PHO#</b>
D.01	Access Ramp Location	Outdoor (to WC)	P.06.1-3
D.02	Rain Protection System	No	
D.03	Number of Inclined Planes	1	
D.04	Number of intermediate Level Landings	0	
D.05	Top Landing Dimensions (Length x Width)	≥1.50m x 1.20m	
D.06	Inclined Plane (Slope-Length x Width)	5% - 3.50m x 1.60m	

<b>(D) ACCESS RAMPS DETAILS – RAMP #03 (&lt; 5%)</b>			
<b>ITEM#</b>	<b>PROVISION DESCRIPTION</b>	<b>CHECKLIST</b>	<b>PHO#</b>
D.01	Access Ramp Location	Outdoor (to Wagon exhibit)	P.06.1-3
D.02	Rain Protection System	No	
D.03	Number of Inclined Planes	1	
D.04	Number of intermediate Level Landings	0	
D.05	Top Landing Dimensions (Length x Width)	≥1.50m x 1.20m	
D.06	Inclined Plane (Slope-Length x Width)	5% - 3.20m x 1.60m	



<b>(E) SIGNAGE INFORMATION</b>			
<b>ITEM#</b>	<b>AREA – SIGNAGE PROVISION</b>	<b>CHECKLIST</b>	<b>PHO#</b>
E.01	Site/Building – Address Number	No	
E.02	Site/Building – Site/Building Name	Yes	P.16.1
E.03	Parking – Disabled Parking Space Symbol	No	
E.04	Parking – International Accessibility Symbol	No	
E.05	Parking – Building Access Ramp Location	No	
E.06	Parking – Site Diagram	No	
E.07	Parking – Directional	Yes	
E.08	Parking – General Information	No	
E.09	Entrance/Reception – Site/Building Diagram	No	
E.10	Entrance/Reception – Directional	No	
E.11	Entrance/Reception – Bathroom Location	No	
E.12	Entrance/Reception – General Information	No	
E.13	Inside Facility – Exhibition Area Labels	Sufficient	P.25
E.14	Inside Facility – Site/Building Diagram	No	
E.15	Inside Facility – Directional	No	
E.16	Inside Facility – Bathroom Location	No	
E.17	Inside Facility – Emergency Exit	Yes (Luminus)	
E.18	Facility’s Outdoor Area – Site/Building Diagram	No	
E.19	Facility’s Outdoor Area – Directional	No	
E.20	Other(Description)	No	

**(F) HEARING & SPEECH IMPAIRED INFORMATION**

<b>ITEM#</b>	<b>AREA – PROVISION DESCRIPTION</b>	<b>CHECKLIST</b>	<b>PHO#</b>
F.01	Qualified Signer	No	
F.02	Sign Languages Spoken	No	
F.03	Reception Design Specific Space	No	
F.04	Visual Emergency Alerting Systems	No	
F.05	Augmenting Systems – ex. Induction Loop	No	
F.06	Augmenting Systems –ex. Fm	No	
F.07	Transforming Systems – ex. Captioned Phone	No	
F.08	Transparent Masks for Covid-19	No	

**(G) VISUALLY IMPAIRED INFORMATION – TACTILE GUIDANCE**

<b>ITEM#</b>	<b>TACTILE PROVISION (FROM – TO)</b>	<b>CHECKLIST</b>	<b>PHO#</b>
G.01	Public Sidewalk to Parking Area	No	
G.02	Public Sidewalk to Entrance	No	
G.03	Parking Area to Entrance	No	
G.04	Reception to Bathrooms	No	
G.05	Reception to other Interior Areas	No	
G.06	Interior Areas to Emergency Exit	No	
G.07	Interior Areas to Outdoor Spaces	No	

**(H) VISUALLY IMPAIRED INFORMATION – BRAILLE SYSTEM & TACTILE DIAGRAMS**

<b>ITEM#</b>	<b>BRAILLE &amp; TACTILE DIAGRAM PROVISION</b>	<b>CHECKLIST</b>	<b>PHO#</b>
H.01	Parking Area – Tactile Site Diagram	No	
H.02	Parking Area – General information in Braille	No	
H.03	Entrance/Reception – Tactile Site Diagram	No	
H.04	Entrance/Reception – Tactile Building Diagram	No	
H.05	Entrance/Recep. – General information in Braille	No	
H.06	Inside Facility – Room Info & Number in Braille	No	
H.07	Room Info & Number Location in Braille	No	
H.08	Outdoor Areas – Tactile Site/Building Diagram	No	
H.09	Outdoor Areas – General Information in Braille	No	



<b>LEGEND</b>		
<b>ITEM#</b>	<b>ABBREVIATION</b>	<b>MEANING</b>
01	CY	Cypriot Dialect Sign Language
02	EN	English Sign Language
03	GR	Greek Sign Language
04	TG	Tactile Guidance
05	INA	Information Not Available
06	N/A	Not Applicable
07	OSS	Out of Specifications
08	r	Radius
09	d	Dimensions
10	(L x W)	Length X Width
11	V	Vehicle Access
12	BF	Basement Floor
13	GF	Ground Floor
14	1 <sup>st</sup>	1 <sup>st</sup> Floor
15	2 <sup>nd</sup>	2 <sup>nd</sup> Floor
16	MF	Mezzanine Floor
17	WCA	Wheelchair Accessible

<b>POSSIBLE ANSWERS</b>		
A.10	Access Ramps	Yes (More info in part D)/ No/ Unnecessary
A.26	Main Entry Door Operation	Motion Activated/ Push Button/ Door Handles
A.27	Main Door Type	Single/Double/Transparent/Opaque/Rotating
A.28	Door Opening Direction	Swing/Outwards/Inwards /Left/Right
B.01	Special Category Type	Listed Building/Archaeological Site/Nature Site
H.07	Info & Number Location	Door Handle Side/ Top/Right/Left/(N/A)
E/G/H	All Provisions	Yes/No/Partial