



<b>(A) GENERAL SITE/BUILDING INFORMATION</b>			
<b>ITEM#</b>	<b>PROVISION DESCRIPTION</b>	<b>CHECKLIST</b>	<b>PHO#</b>
A.01	Number of Floors	1	P.01.1-2
A.02	Receptionist	Yes	
A.03	Qualified Singer / Languages Spoken	No	
A.04	Site Access	Vehicle/Wheel Chair	
A.05	Parking Area Access	Automated	
A.06	Drop Off Point	No	P.02
A.07	Onsite Disabled Parking Spaces (3.30x5.00m)	2 - (3.30X5.00m)	P.03
A.08	Onsite Wheelchair-Accessible Vehicle Parking	No	P.04
A.09	On-Street Disabled Parking (2.70x5.00m)	No	P.05
A.10	Access Ramps	Yes (More info in part D)	P.06
A.11	Lifting Platforms	No	P.07
A.12	Disabled Bathrooms-Dimensions/ Door width	No	P.08
A.13	Disabled Elevators	Yes (More info in part C)	P.09
A.14	Tactile Site/Building Guidance	No	
A.15	Braille Writing System Signage/Tactile Diagrams	No	
A.16	Hearing/Speech Impaired Communication Syst.	No	
A.17	Emergency Alerting Systems	No	
A.18	Staircase Disabled Emergency Waiting Point	No	
A.19	Surface Materials - Parking Area	Asphalt	P.10
A.20	Surface Materials - Entrance	N/A	P.11
A.21	Surface Materials - Reception/Lobby	N/A	P.12
A.22	Surface Materials - Corridors	N/A	P.13
A.23	Surface Materials - Other Indoor Spaces	N/A	P.14
A.24	Surface Materials - Outdoor Gathering Spaces	Concrete	P.15.1-2
A.25	Main Entry Vestibule	N/A	
A.26	Main Entry Door Operation	N/A	
A.27	Main Entry Door Type/ Single Door Width	N/A	
A.28	Main Entry Door Opening Direction	N/A	
A.29	Main Entry Door Threshold Height	N/A	
A.30	Interior Doors Width (min/max width)	N/A	
A.31	Corridor Width (min/max width)	N/A	
A.32	Corridor Widening Point (≥1.80x1.80m)	N/A	
A.33	Drain Covers Types	N/A	P.16
A.34	Indoor Light Intensity(LUX)	INA	
A.35	Outdoor Light Intensity (LUX)	INA	



<b>(B) SITE/BUILDING SPECIAL REQUIREMENTS INFORMATION</b>			
<b>ITEM#</b>	<b>PROVISION DESCRIPTION</b>	<b>CHECKLIST</b>	<b>PHO#</b>
B.01	Special Category Type Site/Building	Open Parking Area	
B.02	Ticket Counter Height/Knee Space (70cm/60cm)	1.07m/0cm	
B.03	Ticket Counter Area (r ≥1.50m) or Dimensions	N/A	P.17
B.04	Disabled Seats	N/A	P.18
B.05	Disabled Seats (Row Location)	N/A	
B.06	Theater Stage/Playing Field Disabled Access	N/A	
B.07	Church Iconostasi Access	N/A	
B.08	Vestibule Dimensions (L x W)	N/A	
B.09	Vestibule Interior Door Operation	N/A	
B.10	Vestibule Interior Door Type/ Single Door Width	N/A	
B.11	Vestibule Interior Door Opening Direction	N/A	
B.12	Playground Accessibility	N/A	P.19
B.13	Special Needs Playground Equipment	N/A	P.20
B.14	Inclusive Site/Building Furnishings	No	P.21
B.15	Other(Description)	No	P.22

<b>(C) ELEVATOR INFORMATION</b>			
<b>ITEM#</b>	<b>PROVISION DESCRIPTION</b>	<b>CHECKLIST</b>	<b>PHO#</b>
C.01	Elevators for Disabled	1	P.09.1-4
C.02	Floor Announcement System	Yes	
C.03	Control Panel with Tactile Numbers & Braille	Yes	
C.04	Warning Floor Strip	Yes	
C.05	Waiting Area (Door – Wall Distance) ≥150cm	Yes	
C.06	Door - Frame Color Contrast	Low	P.09.5-6
C.07	Door Width ≥90cm	Yes	
C.08	Elevator Cabin Dimensions ≥110 x 140cm	Yes	
C.09	Elevator Cabin Dimensions ≥110 x 220cm	Yes	
C.10	Wall Mirror Inside Cabin	Yes	
C.11	Cabin Handrails	Yes	
C.12	Cabin Control Panel (Tactile Numbers/Braille)	Yes	
C.13	Cabin Announcement System	Yes (Language)	
C.14	Cabin Anti-Slip, non-Reflective Floor	Yes	
C.15	Cabin Emergency Communication System	Yes	
C.16	Waiting Area Light Intensity (200 LUX)	INA	



# ACCESSIBILITY INFORMATION | SITE

## Municipal Parking: D'Avila, Nicosia

NIC 017

<b>(D) ACCESS RAMPS DETAILS – RAMP #01 (≥ 5%)</b>			
<b>ITEM#</b>	<b>PROVISION DESCRIPTION</b>	<b>CHECKLIST</b>	<b>PHO#</b>
D.01	Access Ramp Location	Entrance/ Outdoor	P.06.1-4
D.02	Rain Protection System	No	
D.03	Number of Inclined Planes	1	
D.04	Number of intermediate Level Landings	0	
D.05	Top Landing Dimensions (Length x Width)	≥1.50m x 1.20m	
D.06	Top Landing Tactile Warning Strip	Yes	
D.07	Inclined Plane (Slope-Length x Width)	28% - 20.0m x 1.20m	
D.08	Inclined Plane Handrails information	No	
D.09	Inclined Plane Handrails Height (70cm & 90cm)	N/A	
D.10	Inclined Plane - Width between Handrails	N/A	
D.11	Inclined Plane Edge Protection	No	
D.12	Bottom Landing Dimensions (Length x Width)	≥1.50m x 1.20m	
D.13	Bottom Landing Tactile Warning Strip	Yes	

<b>(D) ACCESS RAMPS DETAILS – RAMP #02 (≥ 5%)</b>			
<b>ITEM#</b>	<b>PROVISION DESCRIPTION</b>	<b>CHECKLIST</b>	<b>PHO#</b>
D.01	Access Ramp Location	Entrance/ Outdoor	P.06.5-9
D.02	Rain Protection System	No	
D.03	Number of Inclined Planes	1	
D.04	Number of intermediate Level Landings	0	
D.05	Top Landing Dimensions (Length x Width)	≥1.50m x 1.20m	
D.06	Top Landing Tactile Warning Strip	Yes	
D.07	Inclined Plane (Slope-Length x Width)	28% - 20.0m x 1.20m	
D.08	Inclined Plane Handrails information	No	
D.09	Inclined Plane Handrails Height (70cm & 90cm)	N/A	
D.10	Inclined Plane - Width between Handrails	1.00m	
D.11	Inclined Plane Edge Protection	No	
D.12	Bottom Landing Dimensions (Length x Width)	≥1.50m x 1.20m	
D.13	Bottom Landing Tactile Warning Strip	Yes	
D.14	1 <sup>st</sup> Landing Edge Protection	Yes	
D.15	2 <sup>nd</sup> Inclined Plane (Slope-Length x Width)	5% - 10.0m x 1.20m	
D.16	2 <sup>nd</sup> Inclined Plane Handrails information	Both Sides/One Side/No	
D.17	2 <sup>nd</sup> Inclined Plane Handrails Height (70cm & 90cm)	70cm & 90cm	
D.18	2 <sup>nd</sup> Inclined Plane - Width between Handrails	1.00m	
D.19	2 <sup>nd</sup> Inclined Plane Edge Protection	Yes	
D.20		1.50m x 1.20m	
D.21		No	



<b>(D) ACCESS RAMPS DETAILS – RAMP #03 (&lt; 5%)</b>			
<b>ITEM#</b>	<b>PROVISION DESCRIPTION</b>	<b>CHECKLIST</b>	<b>PHO#</b>
D.01	Access Ramp Location	Entrance/Indoor/Outdoor	P.06.1-3
D.02	Rain Protection System	Yes/No/Indoor	
D.03	Number of Inclined Planes	1	
D.04	Number of intermediate Level Landings	0	
D.05	Top Landing Dimensions (Length x Width)	≥1.50m x 1.20m	
D.06	Inclined Plane (Slope-Length x Width)	4.5% - 10.0m x 1.20m	



<b>(E) SIGNAGE INFORMATION</b>			
<b>ITEM#</b>	<b>AREA – SIGNAGE PROVISION</b>	<b>CHECKLIST</b>	<b>PHO#</b>
E.01	Site/Building – Address Number	No	
E.02	Site/Building – Site/Building Name	No	P.01
E.03	Parking – Disabled Parking Space Symbol	No	
E.04	Parking – International Accessibility Symbol	Yes	
E.05	Parking – Building Access Ramp Location	No	
E.06	Parking – Site Diagram	No	
E.07	Parking – Directional	No	
E.08	Parking – General Information	No	
E.09	Entrance/Reception – Site/Building Diagram	No	
E.10	Entrance/Reception – Directional	No	
E.11	Entrance/Reception – Bathroom Location	No	
E.12	Entrance/Reception – General Information	Yes	
E.13	Inside Facility – Exhibition Area Labels	N/A	P.23
E.14	Inside Facility – Site/Building Diagram	N/A	
E.15	Inside Facility – Directional	N/A	
E.16	Inside Facility – Bathroom Location	N/A	
E.17	Inside Facility – Emergency Exit	N/A	
E.18	Facility’s Outdoor Area – Site Diagram	No	
E.19	Facility’s Outdoor Area – Directional	No	
E.20	Other(Description)	No	



<b>(F) HEARING &amp; SPEECH IMPAIRED INFORMATION</b>			
<b>ITEM#</b>	<b>AREA – PROVISION DESCRIPTION</b>	<b>CHECKLIST</b>	<b>PHO#</b>
F.01	Qualified Signer	No	
F.02	Sign Languages Spoken	CY, GR, EN, No	
F.03	Reception Design Specific Space	No	
F.04	Visual Emergency Alerting Systems	No	
F.05	Augmenting Systems – ex. Induction Loop	No	
F.06	Augmenting Systems –ex. Fm	No	
F.07	Transforming Systems – ex. Captioned Phone	No	
F.08	Transparent Masks for Covid-19	No	

<b>(G) VISUALLY IMPAIRED INFORMATION – TACTILE GUIDANCE</b>			
<b>ITEM#</b>	<b>TACTILE PROVISION (FROM – TO)</b>	<b>CHECKLIST</b>	<b>PHO#</b>
G.01	Public Sidewalk to Parking Area	No	
G.02	Public Side to Entrance	No	
G.03	Parking Area to Entrance	No	
G.04	Reception to Bathrooms	No	
G.05	Reception to other Interior Areas	No	
G.06	Interior Areas to Emergency Exit	No	
G.07	Interior Areas to Outdoor Spaces	No	

<b>(H) VISUALLY IMPAIRED INFORMATION – BRAILLE SYSTEM &amp; TACTILE DIAGRAMS</b>			
<b>ITEM#</b>	<b>BRAILLE &amp; TACTILE DIAGRAM PROVISION</b>	<b>CHECKLIST</b>	<b>PHO#</b>
H.01	Parking Area – Tactile Site Diagram	No	
H.02	Parking Area – General information in Braille	No	
H.03	Entrance/Reception – Tactile Site Diagram	No	
H.04	Entrance/Reception – Tactile Building Diagram	No	
H.05	Entrance/Recep. – General information in Braille	No	
H.06	Inside Facility – Room Info & Number in Braille	No	
H.07	Room Info & Number Location in Braille	No	
H.08	Outdoor Areas – Tactile Site/Building Diagram	No	
H.09	Outdoor Areas – General Information in Braille	No	



LEGEND		
ITEM#	ABBREVIATION	MEANING
01	CY	Cypriot Dialect Sign Language
02	EN	English Sign Language
03	GR	Greek Sign Language
04	TG	Tactile Guidance
05	INA	Information Not Available
06	N/A	Not Applicable
07	OSS	Out of Specifications
08	r	Radius
09	(L x W)	Length X Width
10	V	Vehicle Access
11	BF	Basement Floor
12	GF	Ground Floor
13	1 <sup>st</sup>	1 <sup>st</sup> Floor
14	2 <sup>nd</sup>	2 <sup>nd</sup> Floor
15	MF	Mezzanine Floor